



Corporate Accreditation No 63
Accredited for compliance with ISO/IEC 17025 - Testing



Final Report 281823

Issue Date: 28/03/2023
Issued By : [REDACTED], Commercial Client Representative

Supersedes Report No.: 281515

Attention: [REDACTED]
Customer: Department of Planning and Environment
Customer ID: ZOEH_1

Delivery Address: Sydney Water Corporation
51 Hermitage Rd
West Ryde NSW 2114
Telephone: (02) 9800 6935
Email: analyticalservices@sydneywater.com.au

Address: [REDACTED]
Telephone: 02 9995 5031
Email: oe.h.forensics@environment.nsw.gov.au

CONTENTS

1. Sydney Water Approved Signatory
2. Sample Summary
3. Analytical results
4. Comments
5. Laboratory QC results

Sydney Water Approved Signatory

[REDACTED], Phycology Supervisor	[REDACTED], Organics Analyst
----------------------------------	------------------------------

Where a result is required to meet a compliance limit or specification the associated uncertainty must be considered. Uncertainty estimates are available for all accredited test results.

SAMPLE SUMMARY

<u>Client Sample ID</u>	<u>Sample Number</u>	<u>Sampling Procedure</u>	<u>Date Sampled</u>	<u>Date Received</u>	<u>Date Authorised</u>	<u>Description</u>
231805	L23025072	1	21/03/2023	22/03/2023	27/03/2023	(ENVIRONMENTAL WATER)
231806	L23025073	1	21/03/2023	22/03/2023	27/03/2023	(ENVIRONMENTAL WATER)
231807	L23025074	1	21/03/2023	22/03/2023	27/03/2023	(ENVIRONMENTAL WATER)
231808	L23025075	1	21/03/2023	22/03/2023	27/03/2023	(ENVIRONMENTAL WATER)
231809	L23025076	1	21/03/2023	22/03/2023	27/03/2023	(ENVIRONMENTAL WATER)
231810	L23025077	1	21/03/2023	22/03/2023	27/03/2023	(ENVIRONMENTAL WATER)
231813	L23025078	1	21/03/2023	22/03/2023	24/03/2023	(ENVIRONMENTAL WATER)
231818	L23025079	1	21/03/2023	22/03/2023	24/03/2023	(ENVIRONMENTAL WATER)
231823	L23025080	1	21/03/2023	22/03/2023	24/03/2023	(ENVIRONMENTAL WATER)
231828	L23025081	1	21/03/2023	22/03/2023	24/03/2023	(ENVIRONMENTAL WATER)
231833	L23025082	1	21/03/2023	22/03/2023	24/03/2023	(ENVIRONMENTAL WATER)
231838	L23025083	1	21/03/2023	22/03/2023	24/03/2023	(ENVIRONMENTAL WATER)

Sampling procedures

- 1 Samples analysed as received.
- 2 Samples collected as per FS procedures SAWI 070, Excluding Oil & Grease which is collected as per clients instructions.
- 3 Samples collected as per FS procedures SAWI 070.
- 4 Results reported as received from WNSW.

ANALYTICAL RESULTS

Client Sample ID	231805	231806	231807	231808	231809	231810	231813	231818
Sampled Date	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM	21/03/2023 10:44:00 AM	21/03/2023 11:06:00 AM	21/03/2023 11:28:00 AM	21/03/2023 12:29:00 PM	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM
Sample Number	L23025072	L23025073	L23025074	L23025075	L23025076	L23025077	L23025078	L23025079

ALGAL

MA70CENTI : Total Algal ID & Enumeration, Including ASU & Biovolumes

Blue Green ASU	ASU/mL	-	-	-	-	-	-	2055	4198
Blue Green Biovol	mm3/L	-	-	-	-	-	-	2.84	4.44
Potentially Toxic Algae	cells/mL	-	-	-	-	-	-	28240	39850
Potentially Toxic ASU	ASU/mL	-	-	-	-	-	-	877.2	1308
Potentially Toxic Biovol	mm3/L	-	-	-	-	-	-	0.843	1.45
Potentially Toxic Blue Green	cells/mL	-	-	-	-	-	-	28240	39850
Potentially Toxic Blue Green ASU	ASU/mL	-	-	-	-	-	-	877.2	1308
Potentially Toxic Blue Green Biovol	mm3/L	-	-	-	-	-	-	0.843	1.45
Total Algae	cells/mL	-	-	-	-	-	-	222000	972000
Total ASU	ASU/mL	-	-	-	-	-	-	7919	19760

"-" = Not required or refer to Laboratory comment

Client Sample ID	231805	231806	231807	231808	231809	231810	231813	231818
Sampled Date	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM	21/03/2023 10:44:00 AM	21/03/2023 11:06:00 AM	21/03/2023 11:28:00 AM	21/03/2023 12:29:00 PM	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM
Sample Number	L23025072	L23025073	L23025074	L23025075	L23025076	L23025077	L23025078	L23025079

ALGAL

MA70CENTI : Total Algal ID & Enumeration, Including ASU & Biovolumes(Continued)

Total Biovol	mm3/L	-	-	-	-	-	-	7.7	18.07
Total Blue Green	cells/mL	-	-	-	-	-	-	160600	819100
Total Colonies	cols/mL	-	-	-	-	-	-	0.00	0.00

MA91 : Individual Species Total Count, Total BioVol, Total ASU

Algae Source*	N/A	-	-	-	-	-	-	EXTERNAL	EXTERNAL
Date of Performance	DD/MM/YY							24/03/23 00:00	24/03/23 00:00

ORGANICS

TC0049DWI : Algal Toxins

Anatoxin-a(extracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	-	-
Anatoxin-a(intracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	-	-
Anatoxin-a(total)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	-	-
Cylindrospermopsin (extra cellular)	ug/L	0.07	<0.05	0.07	<0.05	<0.05	<0.05	-	-

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Client Sample ID	231805	231806	231807	231808	231809	231810	231813	231818
Sampled Date	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM	21/03/2023 10:44:00 AM	21/03/2023 11:06:00 AM	21/03/2023 11:28:00 AM	21/03/2023 12:29:00 PM	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM
Sample Number	L23025072	L23025073	L23025074	L23025075	L23025076	L23025077	L23025078	L23025079

ORGANICS

TC0049DWI : Algal Toxins(Continued)

Cylindrospermopsin (intra cellular)	ug/L	0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Cylindrospermopsin(total)	ug/L	0.12	<0.05	0.07	<0.05	<0.05	<0.05	-	-
Microcystin LR(extracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Microcystin LR(intracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Microcystin LR(total)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Microcystin RR(extracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Microcystin RR(intracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Microcystin RR(total)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Microcystin YR(extracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Client Sample ID	231805	231806	231807	231808	231809	231810	231813	231818
Sampled Date	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM	21/03/2023 10:44:00 AM	21/03/2023 11:06:00 AM	21/03/2023 11:28:00 AM	21/03/2023 12:29:00 PM	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM
Sample Number	L23025072	L23025073	L23025074	L23025075	L23025076	L23025077	L23025078	L23025079

ORGANICS

TC0049DWI : Algal Toxins(Continued)

Microcystin YR(intracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Microcystin YR(total)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	-	-
Nodularin (extracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	-	-
Nodularin (intracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	-	-
Nodularin (total)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	-	-
Date of Performance	DD/MM/YY	22/03/23	22/03/23	22/03/23	22/03/23	22/03/23	22/03/23		

TC0061DWI : Paralytic Shellfish Toxins (PST) Analysis by UPLCMSMS

C1	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	-	-
C2	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	-	-
dcGTX2	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	-	-
dcGTX3	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	-	-
dcNeo	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	-	-

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Client Sample ID		231805	231806	231807	231808	231809	231810	231813	231818
Sampled Date		21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM	21/03/2023 10:44:00 AM	21/03/2023 11:06:00 AM	21/03/2023 11:28:00 AM	21/03/2023 12:29:00 PM	21/03/2023 09:52:00 AM	21/03/2023 10:09:00 AM
Sample Number		L23025072	L23025073	L23025074	L23025075	L23025076	L23025077	L23025078	L23025079
ORGANICS									
TC0061DWI : Paralytic Shellfish Toxins (PST) Analysis by UPLCMSMS(Continued)									
dcSTX	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	-	-
GTX1	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	-	-
GTX2	ug/L	<1	<1	<1	<1	<1	<1	-	-
GTX3	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	-	-
GTX4	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	-	-
GTX5	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	-	-
GTX6	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	-	-
Neosaxitoxin	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	-	-
Saxitoxin	ug/L	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	-	-
Date of Performance	DD/MM/YY	26/03/23	26/03/23	26/03/23	26/03/23	26/03/23	26/03/23		

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Client Sample ID		231823	231828	231833	231838				
Sampled Date		21/03/2023 10:44:00 AM	21/03/2023 11:06:00 AM	21/03/2023 11:28:00 AM	21/03/2023 12:29:00 PM				
Sample Number		L23025080	L23025081	L23025082	L23025083				
ALGAL									
MA70CENTI : Total Algal ID & Enumeration, Including ASU & Biovolumes									
Blue Green ASU	ASU/mL	803.4	648.9	223.6	367.5				
Blue Green Biovol	mm3/L	0.902	1.07	0.171	0.384				
Potentially Toxic Algae	cells/mL	1940	4400	637	3320				
Potentially Toxic ASU	ASU/mL	57.1	148.1	23.6	96.4				
Potentially Toxic Biovol	mm3/L	0.054	0.166	0.029	0.092				
Potentially Toxic Blue Green	cells/mL	1940	4400	637	3320				
Potentially Toxic Blue Green ASU	ASU/mL	57.1	148.1	23.6	96.4				
Potentially Toxic Blue Green Biovol	mm3/L	0.054	0.166	0.029	0.092				
Total Algae	cells/mL	401000	197600	101400	128300				
Total ASU	ASU/mL	9642	6024	2885	4342				
Total Biovol	mm3/L	10.42	4.98	2.19	3.85				

* Indicates NATA accreditation does not cover the performance of this service

Client Sample ID		231823	231828	231833	231838				
Sampled Date		21/03/2023 10:44:00 AM	21/03/2023 11:06:00 AM	21/03/2023 11:28:00 AM	21/03/2023 12:29:00 PM				
Sample Number		L23025080	L23025081	L23025082	L23025083				
ALGAL									
MA70CENTI : Total Algal ID & Enumeration, Including ASU & Biovolumes(Continued)									
Total Blue Green	cells/mL	338100	144100	74150	99490				
Total Colonies	cols/mL	0.00	0.00	0.00	0.00				
MA91 : Individual Species Total Count, Total BioVol, Total ASU									
Algae Source*	N/A	EXTERNAL	EXTERNAL	EXTERNAL	EXTERNAL				
Date of Performance	DD/MM/YY	24/03/23 00:00	24/03/23 00:00	24/03/23 00:00	24/03/23 00:00				

COMMENTS

<u>Sample ID</u>	<u>Comment Level</u>	<u>Method</u>	<u>Test</u>	<u>Comment</u>
L23025078	Method	MA91	-	Debris present in the sample.
L23025079	Method	MA91	-	Sample contained debris and cells resembling bacteria.
L23025080	Method	MA91	-	Debris present in the sample.
L23025081	Method	MA91	-	Debris and cells resembling bacteria present in the sample.Sample received partially preserved, results may be compromised
L23025082	Method	MA91	-	Sample received unpreserved/ partially preserved, results may be compromised. Debris present in the sample.
L23025083	Method	MA91	-	Debris present in the sample.

* Indicates NATA accreditation does not cover the performance of this service

LABORATORY QC RESULTS

N/A - Not Applicable

PQL - Practical Quantitation Limit

LOQ - Limit of Quantification

RPD - Relative Percent Difference

SPIKE/Positive Control - Addition of a known amount and concentration

Duplicate Precision = Accepted - Result 2 within 95% confidence limits of result 1

Duplicate Precision = Outlier - Result 2 outside 95% confidence limits of result 1

Duplicate Precision = Not calculated - Result is outside test range

* Indicates NATA accreditation does not cover the performance of this service

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
TC0049DWI Anatoxin-a(extracellular)						
<0.1 ug/L	<0.1	100 <i>50.0 - 120.0 ug/L</i>	85 % Recovery <i>50.0 - 130.0 % Recovery</i>	<0.1	<0.1	B <i>0.0 - 0.0 %</i>
TC0049DWI Anatoxin-a(intracellular)						
<0.1 ug/L	F		E	<0.1	<0.1	B <i>0.0 - 0.0 %</i>
TC0049DWI Anatoxin-a(total)						
<0.1 ug/L	F		E	<0.1	<0.1	B <i>0.0 - 0.0 %</i>
TC0049DWI Cylindrospermopsin (extracellular)						
<0.05 ug/L	<0.05	96 <i>50.0 - 120.0 ug/L</i>	76 % Recovery <i>50.0 - 130.0 % Recovery</i>	0.07	0.08	B <i>0.0 - 0.0 %</i>
TC0049DWI Cylindrospermopsin (intracellular)						
<0.05 ug/L	F		E	0.05	0.06	B <i>0.0 - 0.0 %</i>
TC0049DWI Cylindrospermopsin(total)						
<0.05 ug/L	F		E	0.12	0.14	B <i>0.0 - 0.0 %</i>

* Indicates NATA accreditation does not cover the performance of this service

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
TC0049DWI Microcystin LR(extracellular)						
<0.05 ug/L	<0.05	76 50.0 - 120.0 ug/L	64 % Recovery 50.0 - 130.0 % Recovery	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Microcystin LR(intracellular)						
<0.05 ug/L	F		E	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Microcystin LR(total)						
<0.05 ug/L	F		E	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Microcystin RR(extracellular)						
<0.05 ug/L	<0.05	86 50.0 - 120.0 ug/L	58 % Recovery 50.0 - 130.0 % Recovery	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Microcystin RR(intracellular)						
<0.05 ug/L	F		E	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Microcystin RR(total)						
<0.05 ug/L	F		E	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Microcystin YR(extracellular)						
<0.05 ug/L	<0.05	81 50.0 - 120.0 ug/L	81 % Recovery 50.0 - 130.0 % Recovery	<0.05	<0.05	B 0.0 - 0.0 %

* Indicates NATA accreditation does not cover the performance of this service

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
TC0049DWI Microcystin YR(intracellular)						
<0.05 ug/L	F		E	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Microcystin YR(total)						
<0.05 ug/L	F		E	<0.05	<0.05	B 0.0 - 0.0 %
TC0049DWI Nodularin (extracellular)						
<0.1 ug/L	<0.1	77 50.0 - 120.0 ug/L	71 % Recovery 50.0 - 130.0 % Recovery	<0.1	<0.1	B 0.0 - 0.0 %
TC0049DWI Nodularin (intracellular)						
<0.1 ug/L	F		E	<0.1	<0.1	B 0.0 - 0.0 %
TC0049DWI Nodularin (total)						
<0.1 ug/L	F		E	<0.1	<0.1	B 0.0 - 0.0 %
TC0061DWI C1						
<0.5 ug/L	<0.5	100 70.0 - 130.0 ug/L	120 % Recovery 50.0 - 130.0 % Recovery	<0.5	<0.5	B 0.0 - 0.0 %
TC0061DWI C2						
<0.3 ug/L	<0.3	100 70.0 - 130.0 ug/L	130 % Recovery 50.0 - 130.0 % Recovery	<0.3	<0.3	B 0.0 - 0.0 %

* Indicates NATA accreditation does not cover the performance of this service

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
TC0061DWI dcGTX2						
<0.5 ug/L	<0.5	98 <i>70.0 - 130.0 ug/L</i>	110 % Recovery <i>50.0 - 130.0 % Recovery</i>	<0.5	<0.5	B <i>0.0 - 0.0 %</i>
TC0061DWI dcGTX3						
<0.3 ug/L	<0.3	120 <i>70.0 - 130.0 ug/L</i>	130 % Recovery <i>50.0 - 130.0 % Recovery</i>	<0.3	<0.3	B <i>0.0 - 0.0 %</i>
TC0061DWI dcNeo						
<0.5 ug/L	<0.5	100 <i>70.0 - 130.0 ug/L</i>	82 % Recovery <i>50.0 - 130.0 % Recovery</i>	<0.5	<0.5	B <i>0.0 - 0.0 %</i>
TC0061DWI dcSTX						
<0.5 ug/L	<0.5	100 <i>70.0 - 130.0 ug/L</i>	120 % Recovery <i>50.0 - 130.0 % Recovery</i>	<0.5	<0.5	B <i>0.0 - 0.0 %</i>
TC0061DWI GTX1						
<0.5 ug/L	<0.5	110 <i>70.0 - 130.0 ug/L</i>	100 % Recovery <i>50.0 - 130.0 % Recovery</i>	<0.5	<0.5	B <i>0.0 - 0.0 %</i>
TC0061DWI GTX2						
<1 ug/L	<1	110 <i>70.0 - 130.0 ug/L</i>	130 % Recovery <i>50.0 - 130.0 % Recovery</i>	<1	<1	B <i>0.0 - 0.0 %</i>
TC0061DWI GTX3						
<0.5 ug/L	<0.5	110 <i>70.0 - 130.0 ug/L</i>	130 % Recovery <i>50.0 - 130.0 % Recovery</i>	<0.5	<0.5	B <i>0.0 - 0.0 %</i>

* Indicates NATA accreditation does not cover the performance of this service

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
TC0061DWI GTX4						
<0.3 ug/L	<0.3	120 70.0 - 130.0 ug/L	100 % Recovery 50.0 - 130.0 % Recovery	<0.3	<0.3	B 0.0 - 0.0 %
TC0061DWI GTX5						
<0.5 ug/L	<0.5	110 70.0 - 130.0 ug/L	120 % Recovery 50.0 - 130.0 % Recovery	<0.5	<0.5	B 0.0 - 0.0 %
TC0061DWI GTX6						
<0.3 ug/L	<0.3	110 70.0 - 130.0 ug/L	130 % Recovery 50.0 - 130.0 % Recovery	<0.3	<0.3	B 0.0 - 0.0 %
TC0061DWI Neosaxitoxin						
<0.3 ug/L	<0.3	110 70.0 - 130.0 ug/L	110 % Recovery 50.0 - 130.0 % Recovery	<0.3	<0.3	B 0.0 - 0.0 %
TC0061DWI Saxitoxin						
<0.4 ug/L	<0.4	110 70.0 - 130.0 ug/L	130 % Recovery 50.0 - 130.0 % Recovery	<0.4	<0.4	B 0.0 - 0.0 %

* Indicates NATA accreditation does not cover the performance of this service

Extra Note:

F: Blank is not applicable for this analyte

E: Spike is not applicable for this analyte

DUPLICATE Anatoxin-a(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Anatoxin-a(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Anatoxin-a(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Cyndrospermopsin (extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Cyndrospermopsin (intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Cyndrospermopsin(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin LR(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin LR(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin LR(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin RR(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin RR(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin RR(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin YR(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin YR(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin YR(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Nodularin (extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Nodularin (intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Nodularin (total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE C1 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE C2 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcGTX2 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcGTX3 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcNeo B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcSTX B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX1 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX2 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX3 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX4 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX5 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX6 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Neosaxitoxin B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Saxitoxin B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

* Indicates NATA accreditation does not cover the performance of this service

* Indicates NATA accreditation does not cover the performance of this service